



Certified Product Listing

For:

Drinking Water System Components - Health Effects

Company:

Metal Improvement Co. LLC
(DBA Everlube Products)
80 Route 4 East Suite 310
Paramus, NJ 07652, United States

Plant Location:

Peachtree City, GA, United States

Standards:

NSF/ANSI 61 Section 5

Certificate:

Issued: 06/13/2016
Expires: 12/31/2021

Material/Product:

PTFE Dry Film Lubrication

Contact Temperature:

23 ± 2 C

Models:

Everlube R75



Material Characteristics:

Minimum pipe diameter (inches): 0.5

Maximum pipe surface area/volume ratio (sq in/L): 488

Minimum tank size (gallons): 5

Maximum tank surface area/volume ratio (sq in/L): 40.4

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): Yes

(1) Type of coat: Thinner

(2) Number of additional coats: 1

Total cure time and temperature: 30 mins at 80 °C and 1 hr at 204 °C

Mix ratio: Refer to manufacturer's instructions for details

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes

(1) Certified for use on a new pipe? (Y/N): Yes

(2) Certified for use on a pipe intended for immediate return to service? (Y/N): Yes